


Firm:

| | | |
|---|---|-------------------------|
|  | City of Rocky Mount Addendum 1 | |
| | Refer <u>ALL</u> Inquiries regarding this RFQ to: Candice Kirtz Purchasing Manager | RFQ #320- 040621CK |
| | | RFQ Due Date: 6/24/2021 |
| Contract Type: Professional Services | | |

FAILURE TO RETURN THIS ADDENDUM IN ACCORDANCE WITH INSTRUCTIONS MAY SUBJECT YOUR PROPOSAL TO REJECTION ON THE AFFECTED ITEM(S):

RFQ Schedule Reminder/Addendum Deadline Extension

| Event | Responsibility | Date and Time |
|--|----------------|-----------------------------------|
| Submit Written Questions No Later Than | Designer | Wednesday June 16, 2021 |
| Provide Response to Questions/Addendum | City | Friday June 18, 2021 |
| Submit Qualifications No Later Than | Designer | Thursday June 24, 2021, 4:00 p.m. |
| Contract Award | City | TBD |
| Contract Start Date | Designer | TBD |

Question and Answer

1. Do you anticipate any easement acquisition at a future date for this project or will all of the underground work be within existing ROW or power easement?
 - a. We believe all the work can be done in the existing ROW, but there are some places we may have to acquire ROW.

2. Will this project be just for the electric utilities, or will it include the communications and/or other utilities jointly using the existing poles?
 - a. We could be asked to accommodate other attachers.

3. Has any dates been chosen for when the design needs to be out for bid for construction, and when construction is to begin and end?
 - a. No dates have been decided but since some demotion has begun the clock is ticking. The plan will be for electric only however I think we might be wise to have the plan include two spare conduits per electric run.